

Energy performance certificate (EPC) recommendation report

52-54 Weir Road LONDON SW19 8UG	Report number 2225-0906-7502-9303-9079
	Valid until 29 September 2033

Energy rating and EPC

This property’s energy rating is C.

For more information on the property’s energy performance, [see the EPC for this property \(/energy-certificate/7322-3451-1140-9281-6197\)](#).

Recommendations

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
In some spaces, the solar gain limit defined in the NCM is exceeded, which might cause overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	Medium

Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Consider installing building mounted wind turbine(s).	Low
Consider installing solar water heating.	Low
Add optimum start/stop to the heating system.	Medium

Recommendation	Potential impact on carbon emissions
Consider installing PV.	Low
Some walls have uninsulated cavities - introduce cavity wall insulation.	Medium

Property and report details

Report issued on	30 September 2023
Total useful floor area	958 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	CLG, iSBEM, v6.1.e, SBEM, v6.1.e.0

Assessor's details

Assessor's name	Peter Cowan
Telephone	07702 710 383
Email	petercowan77@yahoo.co.uk
Employer's name	Peter Cowan
Employer's address	154 Merryhill Road , WD23 1DG
Assessor ID	EES/019605
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Elmhurst Energy Systems Ltd

Other reports for this property

If you are aware of previous reports for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related reports for this property.




[Help \(/help\)](/help) [Accessibility \(/accessibility-statement\)](/accessibility-statement) [Cookies \(/cookies\)](/cookies)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5)

[Service performance \(/service-performance\)](/service-performance)

OGI

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



© Crown copyright (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/>)