# **Energy performance certificate (EPC)**

UNIT C6 BOSTON TRADE PARK NORFOLK STREET BOSTON PE21 9HG Energy rating

Valid until:	20 June 2031
Certificate number:	9351-4447-6543-0882- 8853


Property type	B1 Offices and Workshop businesses
Total floor area	267 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

# **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

If newly built	19 A
If typical of the existing stock	55 C

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	24.39
Primary energy use (kWh/m2 per year)	144

## **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/1199-4321-1931-0492-5324)</u>.

#### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Danny Hopkinson
Telephone	07426 081187
Email	danny@homes-property.co.uk

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited	
Assessor's ID	QUID204810	
Telephone	01225 667 570	
Email	info@quidos.co.uk	

## **About this assessment**

Homes Property & Energy Assessments	
The Gate House, Matlock Green, Matlock, DE4 3BT	
The assessor is not related to the owner of the property.	
10 June 2021	
21 June 2021	