# **Energy performance certificate (EPC)**

Unit 1a,1b & 1c Mill Lane Gisburn CLITHEROE BB7 4LN Energy rating

Valid until: 26 June 2028

Certificate number:

0670-0238-1299-9626-6006

Property type B1 Offices and Workshop businesses


Total floor area 575 square metres

# Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

1

31 B

If typical of the existing stock

If newly built

91 D

# Breakdown of this property's energy performance

Main heating fuel	Oil
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	65.75
Primary energy use (kWh/m2 per year)	323

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> report (/energy-certificate/0260-7926-0498-1660-2090).

#### Who to contact about this certificate

### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name Michael Harrison BSc FRICS

# **Contacting the accreditation scheme**

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO002224
Telephone	0330 124 9660
Email	certification@stroma.com

#### About this assessment

Employer	Oaklodge Energy Ltd
Employer address	2a Mount Pleasant Street Oswaldtwistle
Assessor's declaration	The assessor is not related to the owner of the
	property.
Date of assessment	26 June 2018
Date of certificate	27 June 2018