


Property type	General Industrial and Special Industrial Groups
Total floor area	1,608 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## **Energy rating and score**

This property's current energy rating is A+.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

If newly built	13 A
If typical of the existing stock	51 C

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	5
Building emission rate (kgCO2/m2 per year)	-0.24
Primary energy use (kWh/m2 per year)	-6

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the  $\frac{\text{recommendation}}{\text{report}}$  ( $\frac{\text{recommendation}}{\text{recommendation}}$ ).

#### Who to contact about this certificate

### Contacting the assessor

Date of assessment

Date of certificate

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Aaron Batten
Telephone	0196 283 2656
Email	aaronb@shepherdbrombley.co.uk

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA206039
Telephone	020 8772 3649
Email	epc@cibsecertification.org
About this assessment	
Employer	Shepherd Brombley Partnership Ltd
Employer address	Unit 22 Basepoint Business Centre, 1 Winnall
	Valley Road, Winchester SO23 0LD
Assessor's declaration	The assessor is not related to the owner of the
	property.

10 November 2023

13 November 2023