


Property type	Storage or Distribution
Total floor area	200 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built	17 A
If typical of the existing stock	67 C

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	4.86
Primary energy use (kWh/m2 per year)	51

#### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/8959-4108-5422-1785-8519)</u>.

#### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Joe Davies
Telephone	07977 513353
Email	joe.davies@meessolutions.co.uk

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited	
Assessor's ID	LCEA206152	
Telephone	020 8772 3649	
Email	epc@cibsecertification.org	
About this assessment		
Employer	MFFS Solutions Limited	

Employer	MEES Solutions Limited
Employer address	85 Great Portland Street First Floor London W1W 7LT
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	10 April 2024
Date of certificate	25 April 2024