

Energy Performance Certificate

Non-Domestic Building



79 The High Street
DUNMOW
CM6 1AE

Certificate Reference Number:
0070-0331-3380-8593-2006

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the Government's website www.communities.gov.uk/epbd.

Energy Performance Asset Rating

More energy efficient



Net zero CO₂ emissions

A 0-25

B 26-50

C 51-75

D 76-100

E 101-125

F 126-150

G Over 150

◀ 49

This is how energy efficient the building is.

Less energy efficient

Technical information

Main heating fuel: Natural Gas
Building environment: Air Conditioning
Total useful floor area (m²): 101
Building complexity (NOS level): 3

Benchmarks

Buildings similar to this one could have ratings as follows:

59 If newly built

92 If typical of the existing stock

Administrative information

This is an Energy Performance Certificate as defined in SI2007:991 as amended

Assessment Software: iSBEM v3.4.a using calculation engine SBEM v3.4.a

Property Reference: 788323530000

Assessor Name: Stuart Childs

Assessor Number: STRO001584

Accreditation Scheme: Stroma Accreditation Ltd

Employer/Trading Name: Senergi

Employer/Trading Address: 59 Glenfield Road, Luton, Bedfordshire, LU3 2JA

Issue Date: 24 Jul 2009

Valid Until: 23 Jul 2019 (unless superseded by a later certificate)

Related Party Disclosure:

Recommendations for improving the property are contained in Report Reference Number: 0930-7032-0481-3050-3080

If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the certificate. You can get contact details of the accreditation scheme from the Government's website at www.communities.gov.uk/epbd, together with details of the procedures for confirming authenticity of a certificate and for making a complaint.



For advice on how to take action and to find out about technical and financial assistance schemes to help make buildings more energy efficient visit www.carbontrust.co.uk or call us on **0800 085 2005**