


Property type B2 to B7 General Industrial and Special Industrial Groups
Total floor area 852 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

#### **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

# How this property compares to others

Properties similar to this one could have ratings:

If newly built	26 B
If typical of the existing stock	77 D

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	62.67
Primary energy use (kWh/m2 per year)	371

## **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report (/energy-certificate/9990-8946-0483-6790-7000)</u>.

#### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Andy Ogden	
Telephone	07977 070445	
Email	andv@kentepc.co.uk	

Contacting the accreditation scheme
If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd	
Assessor's ID	EES/019679	
Telephone	01455 883 250	
Email	enquiries@elmhurstenergy.co.uk	
About this assessment		
Employer	EPC Solutions (Kent) Partnership	
Employer address	83 Chatham Road, Sandling, Maidstone, Kent ME14 3BB	
Assessor's declaration	The assessor is not related to the owner of the property.	
Date of assessment	13 November 2017	
Date of certificate	15 November 2017	