

Energy performance certificate (EPC)

TWO OFFICE ROOMS QUEENS HOUSE ANNEXE QUEENS ROAD CHESTER CH1 3BQ	Energy rating E	Valid until: 10 November 2030
		Certificate number: 1476-4336-8561-7771-3668

Property type B1 Offices and Workshop businesses


Total floor area 53 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

35 B

If typical of the existing stock

102 E

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	100.62
Primary energy use (kWh/m ² per year)	595

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/2725-7817-4340-9728-2276\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Stephen Allen
Telephone	07806 935 494
Email	steve.allen.nrg@outlook.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/007969
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	NRG Surveyors Ltd
Employer address	19 Clarence Avenue, Chester CH3 5JP
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	11 November 2020
Date of certificate	11 November 2020