Energy performance certificate (EPC)

Rossett Pharmacy Chester Road Rossett	Energy rating	Valid until:	28 May 2032
WREXHAM LL12 0HN		Certificate number:	7479-0063-7389-7702-4976
Property type	A	1/A2 Retail and Fi	nancial/Professional services

Total floor area


80 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

21 A

70 C

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	148.96
Primary energy use (kWh/m2 per year)	881

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/7952-2779-4293-4912-0003).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Ioan Jones
Telephone	07712 235191
Email	ioan@castleepc.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/011777
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Castle EPC	
2 Alyndale, Hope, Wrexham, Clwyd, LL12 9NE	
The assessor is not related to the owner of the	
property.	
26 May 2022	
29 May 2022	