Energy performance certificate (EPC)				
22 College Street ROTHERHAM S65 1AG	Energy rating	Valid until:	3 March 2030	
		Certificate number:	0890-0030-6712-7922-9002	
Property type	A	1/A2 Retail and Fina	ancial/Professional services	

Total floor area


183 square metres

# Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

### How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

40 B

118 E

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	62.33
Primary energy use (kWh/m2 per year)	369

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/0927-2026-1940-8700-9003)</u>.

### Who to contact about this certificate

#### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Andrew Sagar
-----------------	--------------

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd	
Assessor's ID	STRO030142	
Telephone	0330 124 9660	
Email	certification@stroma.com	

#### About this assessment

As Built Energy Surveys	
20 Dovecote, Barnsley	
The assessor is not related to the owner of the	
28 February 2020	
4 March 2020	