

Energy performance certificate (EPC)

LBM Ltd
Green Lane
Wickersley
ROTHERHAM
S66 2BS

Energy rating

D

Valid until: **30 April 2035**

Certificate number: **1723-4766-0071-2406-9797**

Property type **Retail/Financial and Professional Services**


Total floor area **178 square metres**

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

15 A

If typical of the existing stock

60 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	51.58
Primary energy use (kWh/m ² per year)	321

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/6124-3871-8211-5918-3863\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Stephen Goj
Telephone	07711287225
Email	s.goj@nrgfocus.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/024303
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	NRG Focus Ltd
Employer address	info@nrgfocus.co.uk
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	23 April 2025
Date of certificate	1 May 2025