

Energy performance certificate (EPC)

Museum and Visitor Centre Building
Milford Farm
Lifton
PL16 0AT

Energy rating

C

Valid until: 27 May 2031

Certificate number: 2274-3955-1298-3407-4525

Property type

B2 to B7 General Industrial and Special Industrial Groups

Total floor area


4,654 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	19 A
If typical of the existing stock	56 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	38.29
Primary energy use (kWh/m2 per year)	227

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9427-1449-7282-4525-5306\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Daniel Patak
Telephone	0203 397 8220
Email	hello@propcert.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID206065
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	PropCert
Employer address	Provident House, Burrell Row, Beckenham BR3 1AT
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	24 May 2021
Date of certificate	28 May 2021
