Energy performance certificate (EPC)

7600, Daresbury Park Daresbury WARRINGTON WA4 4BS Energy rating

Valid until: 7 June 2030

Certificate number:

0128-0860-1030-2600-1003

Property type

B1 Offices and Workshop businesses

Total floor area


647 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

27 B

If typical of the existing stock

79 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas	
Building environment	Heating and Natural Ventilation	
Assessment level	3	
Building emission rate (kgCO2/m2 per year)	44.34	
Primary energy use (kWh/m2 per year)	260	

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/0060-1261-0410-0200-8084).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Cornelius Ward
Telephone	01942256304
Email	con@cccenergy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO029049
Telephone	0330 124 9660
Email	certification@stroma.com
About this assessment	
Employer	The Energy Team t/a CCC Energy
Employer address	Unit O Armetrona Doint Hindley Croon Wigon WNO

Unit 9 Armstrong Point, Hindley Green, Wigan, WN2
4AU
The assessor is not related to the owner of the property.
2 June 2020
8 June 2020