

2 Fairlawn Enterprise Park Bonehurst Road SALFORDS RH1 5GH Energy rating

Valid until: 19 November 2035

Certificate number: 2060-3119-3050-9897-0621

Property type

Offices and Workshop Businesses

Total floor area


417 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

40 B

10 A

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	6.41
Primary energy use (kWh/m2 per year)	66

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation report}}{(\text{/energy-certificate/1007-3845-6002-0129-6992})}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Angie Duncan
Telephone	07983518849
Email	angie@energyconcerns.net

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID209697
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Energy Cncerns
Unit 7, 1 George Williams Way, Colchester, CO1 2JS
The assessor is not related to the owner of the property.
20 November 2025
20 November 2025