

Energy performance certificate (EPC)

369, Blackpool Old Road
BLACKPOOL
FY3 7LX

Energy rating

G

Valid until: **23 June 2029**

Certificate number: **8307-2246-5529-6527-7613**

Property type

Detached bungalow

Total floor area

96 square metres

Rules on letting this property



You may not be able to let this property

This property has an energy rating of G. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Properties can be let if they have an energy rating from A to E. The [recommendations section](#) sets out changes you can make to improve the property's rating.

Energy rating and score

This property's current energy rating is G. It has the potential to be E.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		
55-68	D		
39-54	E		45 E
21-38	F		
1-20	G	15 G	

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Average
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Wall	Cavity wall, as built, partial insulation (assumed)	Average
Roof	Pitched, 100 mm loft insulation	Average
Roof	Pitched, no insulation (assumed)	Very poor
Roof	Flat, limited insulation (assumed)	Poor
Window	Fully double glazed	Good
Main heating	Room heaters, electric	Very poor
Main heating control	Programmer and appliance thermostats	Good
Hot water	Electric immersion, standard tariff	Very poor
Lighting	Low energy lighting in 58% of fixed outlets	Good
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 558 kilowatt hours per square metre (kWh/m²).

Additional information

Additional information about this property:

- Cavity fill is recommended
-

How this affects your energy bills

An average household would need to spend **£2,953 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £1,029 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2019** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 13,331 kWh per year for heating
- 3,511 kWh per year for hot water

Impact on the environment

This property's current environmental impact rating is F. It has the potential to be E.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year. CO₂ harms the environment.

Carbon emissions

An average household produces **6 tonnes of CO₂**

This property produces **9.0 tonnes of CO₂**

This property's potential production **4.9 tonnes of CO₂**

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Increase loft insulation to 270 mm	£100 - £350	£91
2. Flat roof or sloping ceiling insulation	£850 - £1,500	£183
3. Cavity wall insulation	£500 - £1,500	£172
4. Floor insulation (suspended floor)	£800 - £1,200	£308
5. High heat retention storage heaters	£2,400 - £3,600	£68
6. Solar water heating	£4,000 - £6,000	£169

Step	Typical installation cost	Typical yearly saving
7. High performance external doors	£1,000	£37
8. Solar photovoltaic panels	£5,000 - £8,000	£307

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Carl McGrath
Telephone	07828 839 712
Email	carlmcgrath@blueyonder.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID200580
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	24 June 2019
Date of certificate	24 June 2019
Type of assessment	RdSAP
