

# Energy performance certificate (EPC)

<p>GROUND FLOOR Building 3, Venture Court Waterside Business Park Clos Llyn Cwm, Swansea Enterprise Park SWANSEA SA6 8AH</p>	<p>Energy rating</p> <h1>D</h1>	<p>Valid until: <b>11 June 2029</b></p> <p>Certificate number: <b>9899-3066-0816-0401-2491</b></p>
--------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------	----------------------------------------------------------------------------------------------------

Property type **B1 Offices and Workshop businesses**

Total floor area **804 square metres**

## Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

## Energy efficiency rating for this property

This property's current energy rating is D.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO<sub>2</sub>) your property is likely to emit.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

**31 | B**

If typical of the existing stock

**103 | E**

---

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
-------------------	---------------------------

---

Building environment	Air Conditioning
----------------------	------------------

---

Assessment level	4
------------------	---

---

Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year)	50.36
---------------------------------------------------------------------	-------

---

Primary energy use (kWh/m <sup>2</sup> per year)	298
--------------------------------------------------	-----

---

---

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0281-0441-9869-9696-4002\)](#).

---

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	Nicholas Withey
Telephone	07903266468
Email	<a href="mailto:nick@bpslimited.co.uk">nick@bpslimited.co.uk</a>

### Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO005853
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### Assessment details

Employer	Building & Property Surveys Ltd.
Employer address	First Floor, 15 Nevill Street, Abergavenny, NP7 5AA
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	12 June 2019
Date of certificate	12 June 2019

---