

# Energy performance certificate (EPC)

Unit 10  
Falstone Close  
North Tyne Industrial Estate  
BENTON  
NE12 9SZ

Energy rating

**C**

Valid until: **26 February 2033**

Certificate number: **1572-9679-8159-3248-3956**

Property type

Storage or Distribution

Total floor area


4269 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## Energy efficiency rating for this property

This property's current energy rating is C.



Properties are also given a score. The larger the number, the more carbon dioxide (CO<sub>2</sub>) your property is likely to emit.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

14 | A

If typical of the existing stock

56 | C

Properties are given a rating from A+ (most efficient) to G (least efficient).

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
-------------------	---------------------------

---

Building environment	Air Conditioning
----------------------	------------------

---

Assessment level	3
------------------	---

---

Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year)	26.83
---	-------

---

Primary energy use (kWh/m <sup>2</sup> per year)	267
--	-----

---

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/8083-1805-9387-4629-1662\)](/energy-certificate/8083-1805-9387-4629-1662).

---

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	Matthew Ternent
Telephone	01916053482
Email	<a href="mailto:matthewternent@georgefwhite.co.uk">matthewternent@georgefwhite.co.uk</a>

### Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/021753
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### Assessment details

Employer	Johnson Tucker
Employer address	The Boathouse, Newburn, Newcastle upon Tyne
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	24 February 2023
Date of certificate	27 February 2023

---