
Energy performance certificate (EPC)			
Unit 5b Churchill Way Chapeltown	Energy rating	Valid until:	12 November 2027
SHEFFIELD S35 2PY		Certificate number:	9306-3030-0939-0690-9971
Property type	В	1 Offices and Works	shop businesses
Total floor area	468 square metres		

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

34 B

101 E

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	41.99
Primary energy use (kWh/m2 per year)	246

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/0930-0643-0999-6370-9092)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Michael Goodchild
Telephone	0115 714 1123
Email	michael@surveyhub.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/007980
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Survey Hub Ltd	
34 Regent Street, Nottingham, NG1 5BT	
The assessor is not related to the owner of the property.	
31 October 2017	
13 November 2017	