Energy performance certificate (EPC)

Unit 2 Jubilee Park First Avenue DONCASTER DN9 3RW Energy rating

Valid until: 20 August 2033

Certificate number:

7098-9410-2082-9605-0973

Property type

B2 to B7 General Industrial and Special Industrial Groups

Total floor area


1,281 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is A.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	25 A
If typical of the existing stock	72 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	4
Building emission rate (kgCO2/m2 per year)	9.72
Primary energy use (kWh/m2 per year)	72

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/6511-4371-8200-5190-2643).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Oyon Hussain
Telephone	01159 765 050
Email	oyon.hussain@focus-consultants.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

st Energy Systems Ltd
5583
83 250
s@elmhurstenergy.co.uk
Consultants 2010 LLP
louse, Millennium Way West
essor is not related to the owner of the property.
ıst 2023
H