


Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's current energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

1 of 3 22/08/2023, 13:58

How this property compares to others

Properties similar to this one could have ratings:

If newly built	21 A
If typical of the existing stock	61 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	43.3
Primary energy use (kWh/m2 per year)	256

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/0143-3800-7343-0321-3128)</u>.

2 of 3 22/08/2023, 13:58

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Naphtali Lewis
Telephone	020 8458 7444
Email	n.lewis@cecenergy.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited	
Assessor's ID	QUID203288	
Telephone	01225 667 570	
Email	info@quidos.co.uk	
About this assessment		
Employer	CEC Energy Ltd	

Employer	CEC Energy Ltd
Employer address	62 Woodville Road, London, NW11 9TN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	15 March 2022
Date of certificate	16 March 2022

3 of 3 22/08/2023, 13:58