

Air conditioning inspection certificate

5 Wormwood Street
LONDON
EC2M 1RQ

Certificate number
0442-1467-3002-0125-0706

Valid until
24 May 2028

Assessment details

Inspection date	24 May 2023
Inspection level	Level 3
Assessment software	Sterling Accreditation, Sterling e-Volve, v1.2
Assessor's declaration	Not related to the owner/occupier or person who has technical control of the system or subcontractor.
F-Gas compliant date	19 January 2023
Total effective rated output	21 kW
System sampling	No
Treated floor area	160 square metres
Subsystems metered	No
Total estimated refrigerant charge	12 kg

Inspection report

For the assessor's recommendations, [see the inspection report \(/energy-certificate/2430-5015-1070-7402-4025\)](/energy-certificate/2430-5015-1070-7402-4025).

Subsystems inspected

Subsystem ID	Description	Refrigerant type	Age of main components
VOL001/SYS001 Shop Floor	MHI Split System	R410A	2016

Assessor's details

Assessor's name	Benjamin Miller
Email	info@greenzonesurveys.com
Assessor ID	STER003058
Employer/Trading name	Green Zone Surveys (UK) Ltd
Employer/Trading address	Second Floor, Cobalt Business Exchange, Cobalt Park Way, Newcastle Upon Tyne, NE28 9NZ
Accreditation scheme	Sterling Accreditation Ltd
Accreditation scheme telephone	0161 727 4303
Accreditation scheme email	info@sterlingaccreditation.com
