

Air conditioning inspection certificate

Victoria House
1 Leonard Circus
London
EC2A 4DQ

Certificate number
2748-8167-6002-0909-0596

Valid until
2 November 2028

Assessment details

Inspection date	3 November 2023
Inspection level	Level 3
Assessment software	Sterling Accreditation, Sterling e-Volve, v1.2
Assessor's declaration	Not related to the owner/occupier or person who has technical control of the system or subcontractor.
F-Gas compliant date	31 August 2023
Total effective rated output	252 kW
System sampling	Yes
Treated floor area	1,671 square metres
Subsystems metered	Yes
Total estimated refrigerant charge	172 kg

Inspection report

For the assessor's recommendations, [see the inspection report \(/energy-certificate/2460-5299-8070-5198-7005\)](/energy-certificate/2460-5299-8070-5198-7005).

Subsystems inspected

Subsystem ID	Description	Refrigerant type	Age of main components
VOL001/SYS001 2ND FLOOR ZONE 2	Mitsubishi VRF System	R410A	2016
VOL001/SYS002 2ND FLOOR ZONE 1	Mitsubishi VRF System	R410A	2017
VOL001/SYS003 FIRST FLOOR WEST	Mitsubishi VRF System	R410A	2018

Assessor's details

Assessor's name	Syed Shah
Email	syed@cliftonenergy.co.uk
Assessor ID	STER500255
Employer/Trading name	Clifton Energy
Employer/Trading address	New House Farm, Antlands Lane, Burstow, Horley, Surrey, RH6 9TF
Accreditation scheme	Sterling Accreditation Ltd
Accreditation scheme telephone	0161 727 4303
Accreditation scheme email	info@sterlingaccreditation.com