UNIT 2E Zetland House 5-25 Scrutton Street LONDON EC2A 4HJ Energy rating Certificate Certificate number: Valid until: 25 September 2032 Certificate number: 8225-8641-9978-4026-8842

Property type Offices and Workshop Businesses


Total floor area 262 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's current energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

1 of 3

How this property compares to others

Properties similar to this one could have ratings:

If newly built	14 A
If typical of the existing stock	57 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	4
Building emission rate (kgCO2/m2 per year)	9.4
Primary energy use (kWh/m2 per year)	103

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/8794-0338-4989-2870-4961).

2 of 3

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	M M Rauf
Telephone	07878 466 055
Email	muj_is@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd	
Assessor's ID	STRO001523	
Telephone	0330 124 9660	
Email	certification@stroma.com	

About this assessment

Employer	Commercial EPC Ltd
Employer address	www.lepcco.co.uk
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	13 September 2022
Date of certificate	26 September 2022

3 of 3