
Energy performance certificate (EPC)				
641 Maidstone Road ROCHESTER ME1 3QJ	Energy rating	Valid until:	25 September 2033	
METSQJ		Certificate number:	5420-9412-0030-7000-0783	
Property type General Industrial and Special Industrial Groups				
Total floor area	444 square metres			

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

16 A

64 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	15.77
Primary energy use (kWh/m2 per year)	164

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/0915-0204-0407-2708-4004).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Shayn Bennett	
Telephone	01225753755	
Email	info@greenrockenergy.co.uk	

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID206866
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	GreenRock Energy	
Employer address	11 Dunkirk Business Park, Southwick, Trowbridge,	
	Wiltshire, BA14 9NL	
Assessor's declaration	The assessor is not related to the owner of the property.	
Date of assessment	13 September 2023	
Date of certificate	26 September 2023	