Energy performance certificate (EPC)

Anchor Storage Eye Road KENTON IP14 6JJ Energy rating

Valid until: 29 December 2034

Certificate number: 2210-3182-8040-3394-0071

Property type Storage or Distribution


Total floor area 5,140 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If typical of the existing stock

If newly built

0 A

59 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	3.52
Primary energy use (kWh/m2 per year)	38

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation report}}{(\frac{\text{recommendation 1024-8344-1002-0872-0392}}{\text{recommendation 1024-8344-1002-0872-0392}}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mike Simpson
Telephone	(0)7770 580 902
Email	mike@epcmarketing.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID201186
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	EPC Marketing Ltd
Employer address	36B Bredfield St., Woodbridge, IP12 4NH
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	30 December 2024
Date of certificate	30 December 2024