
Energy performance certificate (EPC)				
Lawrence House	Energy rating	Valid until:	17 August 2033	
Magdalen Street Eye IP23 7AJ		Certificate number:	9013-2082-9805-2090- 5328	
Property type		Offices and Worksh	op Businesses	
Total floor area		447 square metres		

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock



Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	25.36
Primary energy use (kWh/m2 per year)	265

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/8201-4909-0015-5224-8653)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Matthew Larner	
Telephone	07969283896	
Email	mjlarner@hotmail.com	

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/028109
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Matthew Larner
110 Sherwood Gardens, London, E14 9WW
The assessor is not related to the owner of the property.
18 July 2023
18 August 2023