

Energy performance certificate (EPC)

1 Parker Court
Staffordshire Technology Park
STAFFORD
ST18 0WP

Energy rating

B

Valid until:

24 March 2034

Certificate
number:

**0256-2309-1868-2951-
3036**

Property type

Offices and Workshop Businesses

Total floor area

2,604 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

11 A

If typical of the existing stock

42 B

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	11.87
Primary energy use (kWh/m ² per year)	129

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/3183-1757-6336-3332-6265\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Sebastian Ingham
Telephone	07817728156
Email	sebastian@idea-ingham.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/022597
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	IDEA Ingham Energy Ltd.
Employer address	Bank House, Longden, Shrewsbury, SY5 8ES
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	20 March 2024
Date of certificate	25 March 2024