# **Energy performance certificate (EPC)**




Property type	A1/A2 Retail and Financial/Professional services		
Total floor area	65 square metres		

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

#### How this property compares to others

Properties similar to this one could have ratings:

If newly built	29 B
If typical of the existing stock	85 D

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity	
Building environment	Air Conditioning	
Assessment level	3	
Building emission rate (kgCO2/m2 per year)	116.61	
Primary energy use (kWh/m2 per year)	690	

## Recommendation report

Guidance on improving the energy performance of this property can be found in the  $\underline{\text{recommendation}}$   $\underline{\text{report (/energy-certificate/1814-3320-0882-3628-4601)}}$ .

## Who to contact about this certificate

**Contacting the assessor** If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Michael Robeson
Telephone	01473 829672
Email	robesonm@energy-evaluations.co.uk

Contacting the accreditation scheme
If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008329
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment Employer	Energy Evaluations & Solutions Ltd.
Employer address	Hadleigh Business Centre, Crockatt Road, Hadleigh, Ipswich, IP7 6RH
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	14 April 2021
Date of certificate	16 April 2021