

Display energy certificate (DEC)



Community Health Partnerships
The Mary Potter Centre
Gregory Boulevard
NOTTINGHAM
NG7 5HY

Operational rating

C

Certificate number: 9097-3219-9192-0908-2264

Valid until: 31 October 2023

Total useful floor area: 7991 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C	69 C	
76-100	D		
			100
101-125	E		
126-150	F		
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	53.10	142.38
Typical energy use (kWh/m ² /year)	78.58	202.63
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
November 2022	69 C
October 2021	66 C
November 2020	76 D

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
November 2022	233	221	0
October 2021	229	226	0
November 2020	236	232	0

Assessment details

Assessor's name	Wayne Allen
Employer/Trading name	Community Health Partnerships
Employer/Trading address	Suite 12B, Manchester One, 53 Portland Street, Manchester M1 3LD
Assessor's declaration	Employed by the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	1 November 2022
Nominated date	1 November 2022

