

Energy performance certificate (EPC)

80 High Street
KING'S LYNN
PE30 1BB

Energy rating

C

Valid until:

23 March 2031

Certificate number: 2759-7881-4021-5643-2822

Property type	A1/A2 Retail and Financial/Professional services
Total floor area	217 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built	30 B
If typical of the existing stock	88 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	100.98
Primary energy use (kWh/m2 per year)	597

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/6176-0822-2671-1506-0893\).](#)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Richard Quantrill
Telephone	07740177672
Email	richard.quantrill@nsc.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008161
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Richard Quantrill
Employer address	13 Marine Drive, Brighton, East Sussex, BN2 7HJ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	9 March 2021
Date of certificate	24 March 2021