
Energy performance certificate (EPC)			
Unit 25 Cannock Shopping Center CANNOCK	Energy rating	Valid until:	17 October 2032
CANNOCK WS11 1WS		Certificate number:	1586-5271-1237-1341-9422
Property type	F	Retail/Financial and F	Professional Services
Total floor area	144 square metres		

# Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

# **Energy rating and score**

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

14 A

58 C

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	20.45
Primary energy use (kWh/m2 per year)	210

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/3285-1514-5300-6187-4270).

### Who to contact about this certificate

#### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Martin Zambrano	
Telephone	01335300928	
Email	martin@luisandbell.co.uk	

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STR0033214
Telephone	0330 124 9660
Email	certification@stroma.com

#### About this assessment

Luis and Bell Surveyors Ltd	
Ashbourne Business Centre Dig Street Ashbourne	
Derbyshire DE6 1GF	
The assessor is not related to the owner of the property.	
20 June 2022	
18 October 2022	