

Energy performance certificate (EPC)

Unit 1 E - F
Westbridge Industrial Estate
Tavistock
PL19 8DE

Energy rating

C

Valid until: **18 August 2031**

Certificate number: **2685-8643-4506-2995-6421**

Property type

A1/A2 Retail and Financial/Professional services

Total floor area

267 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's current energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

22 A

If typical of the existing stock

65 C

Breakdown of this property's energy performance

Main heating fuel

Natural Gas

Building environment

Heating and Natural Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

80.69

Primary energy use (kWh/m² per year)

473

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/1392-8251-8389-9283-5409\)](/energy-certificate/1392-8251-8389-9283-5409).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name Keith Austin

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO000300
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	Austin Energy Services
Employer address	Waratah Bickleigh Plymouth PL6 7AH
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	17 August 2021
Date of certificate	19 August 2021
