

# Energy performance certificate (EPC)

23b Davenant Road  
LONDON  
N19 3NW

Energy rating

C

Valid until: 23 July 2029

Certificate number: 8601-6723-6920-8344-3926

Property type

Mid-floor flat

Total floor area

52 square metres

## Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be C.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C	69   c	80   c
55-68	D		
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says “assumed”, it means that the feature could not be inspected and an assumption has been made based on the property’s age and type.

Feature	Description	Rating
Walls	Solid brick, as built, no insulation (assumed)	Very poor
Windows	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, no room thermostat	Very poor
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	(another dwelling below)	N/A
Secondary heating	None	N/A

## Primary energy use

The primary energy use for this property per year is 232 kilowatt hours per square metre (kWh/m2).

[What is primary energy use?](#)

## Environmental impact of this property

This property's current environmental impact rating is D. It has the potential to be B.

Properties are rated in a scale from A to G based on how much carbon dioxide (CO2) they produce.

Properties with an A rating produce less CO2 than G rated properties.

Current average household CO2 production	6 tonnes of CO2
Current property produces	2.1 tonnes of CO2
Current property’s potential reduction	1.1 tonnes of CO2

By making the [recommended changes](#), you could reduce this property’s CO2 emissions by 1.0 tonnes per year. This will help to protect the environment.


Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from C (69) to C (80).

[What is an energy rating?](#)



### Recommendation 1: Internal or external wall insulation

Internal or external wall insulation

Typical installation cost

£4,000 - £14,000

Typical yearly saving

£148

Potential rating after carrying out recommendation 1

78 | C

### Recommendation 2: Heating controls (room thermostat and TRVs)

Heating controls (room thermostat and TRVs)

Typical installation cost

£350 - £450

Typical yearly saving

£25

Potential rating after carrying out recommendations 1 and 2

79 | C

### Recommendation 3: Replace boiler with new condensing boiler

Condensing boiler

Typical installation cost

£2,200 - £3,000

**Typical yearly saving**

**£18**

**Potential rating after carrying out recommendations 1 to 3**

**80 | C**

## Looking for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

**Estimated energy use and potential savings**

**Estimated yearly energy cost for this property**

**£509**

**Potential saving**

**£191**

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

**Estimated energy used to heat this property**

**Space heating**

**4912 kWh per year**

**Water heating**

**1728 kWh per year**

## Potential energy savings by installing insulation

**Type of insulation**

**Amount of energy saved**

**Walled wall insulation**

**2896 kWh per year**

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

## Contacting the assessor and accreditation scheme

is EPC was created by a qualified energy assessor.

ou are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

ou are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

creditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

Assessor's name	Mahmut Dede
Telephone	0203 397 8220
Email	<a href="mailto:help@epconline.co.uk">help@epconline.co.uk</a>

## Accreditation scheme contact details

Accreditation scheme	Quidos Limited
Assessor ID	QUID207039
Telephone	01225 667 570
Email	<a href="mailto:info@quidos.co.uk">info@quidos.co.uk</a>

## Assessment details

Assessor's declaration	No related party
Date of assessment	24 July 2019
Date of certificate	24 July 2019
Type of assessment	► <a href="#">RdSAP</a>

**Other certificates for this property**

If you are aware of previous certificates for this property and they are not listed here, please contact us at [iclg.digital-services@communities.gov.uk](mailto:iclg.digital-services@communities.gov.uk) or call our helpdesk on 020 3829 0748.

**Energy certificate number**

[2508-0093-6226-6231-7080 \(/energy-certificate/2508-0093-6226-6231-7080\)](#)

**Expiry date**

22 June 2019

---