

Energy performance certificate (EPC)

217 Gosport Road
FAREHAM
PO16 0QE

Energy rating

D

Valid until: **18 February 2035**

Certificate number: **8907-6601-8919-3271-7540**

Property type **Offices and Workshop Businesses**


Total floor area **172 square metres**

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

12 A

If typical of the existing stock

49 B

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	16.4
Primary energy use (kWh/m ² per year)	115

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/2998-8857-9025-1567-0494\)](/energy-certificate/2998-8857-9025-1567-0494).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Rachel Ruthven
Telephone	07854307558
Email	rachelruthven@energysolutionsouth.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/028160
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	
Employer address	
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	17 February 2025
Date of certificate	19 February 2025
