


# Energy Performance Certificate

Non-Domestic Building



6, Cleveland Terrace, Bath BA1 5DF

Bath

BA1 5DF

Certificate Reference Number:

6854-4765-0423-0716-6050

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information in the guidance document *Energy Performance Certificates for the construction, sale and let of non-dwellings* available on the Government's website at [www.gov.uk/government/collections/energy-performance-certificates](http://www.gov.uk/government/collections/energy-performance-certificates).

## Energy Performance Asset Rating

More energy efficient



Net zero CO<sub>2</sub> emissions

A 0-25

B 26-50

C 51-75

D 76-100

E 101-125

F 126-150

G Over 150

◀ 130

This is how energy efficient the building is.

Less energy efficient

## Technical information

Main heating fuel:	Grid Supplied Electricity
Building environment:	Heating and Natural Ventilation
Total useful floor area (m <sup>2</sup> ):	123.3
Building complexity:	Level 3
Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year):	33.16
Primary energy use (kWh <sub>m</sub> /m <sup>2</sup> per year):	341.97

## Benchmarks

Buildings similar to this one could have ratings as follows:

0 If newly built

88 If typical of the existing stock

## Administrative information

This is an Energy Performance Certificate as defined in the Energy Performance of Buildings Regulations 2012 as amended.

**Assessment Software:** iSBEM v6.1.e using calculation engine SBEM v6.1.e.0

**Property Reference:** UPRN-000000000000

**Assessor Name:** Alexander Marcelle

**Assessor Number:** QUID208951

**Accreditation Scheme:** Quidos Limited

**Assessor Qualifications:** NOS4

**Employer/Trading Name:** Alexander Marcelle

**Employer/Trading Address:** 2 Old Printworks

**Issue Date:** 13 Feb 2025

**Valid Until:** 12 Feb 2035 (unless superseded by a later certificate)

**Related Party Disclosure:** Not related to the owner

Recommendations for improving the energy performance of the building are contained in the associated Recommendation Report: 8842-0607-4577-4523-3744

## About this document and the data in it

This document has been produced following an energy assessment undertaken by a qualified Energy Assessor, accredited by Quidos Limited. You can obtain contact details of the Accreditation Scheme at [www.quidos.co.uk](http://www.quidos.co.uk).

A copy of this certificate has been lodged on a national register as a requirement under the Energy Performance of Buildings Regulations 2012 as amended. It will be made available via the online search function at [www.ndepcregister.com](http://www.ndepcregister.com). The certificate (including the building address) and other data about the building collected during the energy assessment but not shown on the certificate, for instance heating system data, will be made publicly available at [www.opendatacommunities.org](http://www.opendatacommunities.org).

This certificate and other data about the building may be shared with other bodies (including government departments and enforcement agencies) for research, statistical and enforcement purposes. For further information about how data about the property are used, please visit [www.ndepcregister.com](http://www.ndepcregister.com). To opt out of having information about your building made publicly available, please visit [www.ndepcregister.com/optout](http://www.ndepcregister.com/optout).

There is more information in the guidance document *Energy Performance Certificates for the construction, sale and let of non-dwellings* available on the Government website at:

[www.gov.uk/government/collections/energy-performance-certificates](http://www.gov.uk/government/collections/energy-performance-certificates). It explains the content and use of this document and advises on how to identify the authenticity of a certificate and how to make a complaint.

## Opportunity to benefit from a Green Deal on this property

The Green Deal can help you cut your energy bills by making energy efficiency improvements at no upfront costs. Use the Green Deal to find trusted advisors who will come to your property, recommend measures that are right for you and help you access a range of accredited installers. Responsibility for repayments stays with the property - whoever pays the energy bills benefits so they are responsible for the payments.

To find out how you could use Green Deal finance to improve your property please call 0300 123 1234.

# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

Certificate No.

451

Page 1 of 15

CLIENT DETAILS		INSTALLATION ADDRESS	
MR S WATSON		WALCOT UPHOLSTERY	
21 PARKFIELDS		1 CLEVELAND TERRACE	
CHIPPENHAM		BATH	
WILTSHIRE		AVON	
Postcode		Postcode	
PURPOSE FOR WHICH THIS REPORT IS REQUIRED			
CLIENTS REQUEST			
Date(s) on which inspection and testing was carried out: 12/3/2025			
DESCRIPTION OF PREMISES			
Domestic <input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Other (include description)			
Estimated age of the wiring system: Years 40			
Evidence of Alterations / Additions: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Not apparent <input type="checkbox"/> If 'Yes' estimate age in years 5			
Date of last inspection: 1/2022 Records available: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
Extent of electrical installation covered by this report		Agreed Limitations (See Reg 653.2)	
CONSUMER UNITS, SUPPLIERS			
EQUIPMENT, EARTHING			
ARRANGEMENTS, FINAL		Agreed with	
CIRCUITS GROUND FLOOR		Operational limitations	
STORAGE ROOM & TOILET BELOW			
It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground, have <b>not</b> been inspected unless specifically agreed between the client and the inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment. This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations), as amended to:			
SUMMARY OF THE CONDITION OF THE INSTALLATION			
General condition of the installation (in terms of electrical safety)			
SUITABLE FOR CONTINUED SERVICE			
Overall assessment of the installation in terms of its suitability for continued use: Satisfactory <input checked="" type="checkbox"/> Unsatisfactory* <input type="checkbox"/>			
*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.			
RECOMMENDATIONS & NEXT INSPECTION			
Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (Code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration.			
Subject to the necessary remedial action being taken, I/we recommend that this installation is further inspected and tested by (Date)			
for the following reasons			
DECLARATION			
I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations of this report.			
Inspected and tested by:		Report authorised for issue by:	
Name Capitals C ARCHER	Date 12/3/25	Name Capitals C ARCHER	Date 14/3/25
Signature		Signature	
For/on behalf of C R ARCHER ELECTRICAL LTD		For/on behalf of	
Position INSPECTOR		Position	
Address 14 ESMEAD, CHIPPENHAM		Address	
WILTSHIRE SN153PS			
CP Scheme: N/A <input checked="" type="checkbox"/>		Membership No:	



## CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

**Certificate No.**

451

Page 2 of 15

## SUPPLY CHARACTERISTICS & EARTHING ARRANGEMENTS

Earthing Arrangements		Number of Live Conductors	Nature of Supply Parameters
TN-C	TN-S ✓	Phase 3 Wire 4 AC <input checked="" type="checkbox"/> DC <input type="checkbox"/>	Nominal Voltage $U/U_0$ 230/230 V
TN-C-S	TT	Other	Nominal Frequency $f^*$ 50 Hz
IT		Confirmation of supply polarity ✓	Prospective fault current $I_{pf}^\dagger$ 1.99 kA
Supply Protective Device Characteristics			External loop impedance $Z_s^\dagger$ 0.11 $\Omega$
Type 1361		Nominal current rating 100 A	* by enquiry    † by enquiry or by measurement ✓
Other sources of supply (as detailed on attached schedule) N/A			

## PARTICULARS OF INSTALLATION REFERRED TO IN THE REPORT

Means of Earthing		Details of Installation Earth Electrode (where applicable)	
Distributor's facility	<input checked="" type="checkbox"/>	Type [eg. rod(s) tape etc]	
Installation earth electrode	<input type="checkbox"/>	Electrode resistance to Earth	Ω
		Location	

## Main Protective Conductors

Earthing conductor:	Material <i>Copper</i>	csa <i>16</i> mm <sup>2</sup>	Continuity and connection verified	<input checked="" type="checkbox"/>
Main protective bonding conductors: (to extraneous-conductors-parts)	Material	csa      mm <sup>2</sup>	Continuity and connection verified	<input type="checkbox"/>
To water installation pipes <input type="checkbox"/>	To gas installation pipes <input type="checkbox"/>	To oil installation pipes <input type="checkbox"/>	To structural steel	<input type="checkbox"/>
To lightning protection <input type="checkbox"/>	To other <input type="checkbox"/> Specify			

**Main Switch / Switch - Fuse / Circuit-Breaker / RCD**

BS, Type	60947-3 5419	No. of poles	2	Voltage rating	230 V
Location	GRD FLOOR MECHAN COPIER	Current rating	100 A	Fuse / device rating or setting	N/A
If RCD main switch: Rated residual operating current $I_{\Delta n}$ =			mA	Type	
			Rated time delay		ms
			Measured operating time		ms

## OBSERVATIONS

Referring to the attached schedules of inspection and test results, and subject to the limitations specified at the **Extent and limitations of inspection and testing** section. No remedial action is required ☐ The following observations are made ☐ See below

[illegible]

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action. **C1** - Danger present. Risk of injury. Immediate remedial action required.

**C2** - Potentially dangerous - urgent remedial action required **C3** - Improvement recommended **F1** - Further investigation required without delay.

## Schedules

The attached Schedules are part of this document and this Certificate is valid only when they are attached to it.

No. of Inspection Schedules attached: 8	No. of Test Result Schedules attached: 3
---	--





# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

Certificate No.

451

Page 3 of 15

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item	Description	Outcome (Use codes above. Provide additional comment where appropriate. C1, C2, C3 & FI coded items to be recorded under observations in the Condition Report)										
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)											
1.1	Service cable	✓										
1.2	Service head	✓										
1.3	Earthing arrangements	✓										
1.4	Meter tails	✓										
1.5	Metering equipment	✓										
1.6	Isolator (where present)	N/A										
Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and/or duty holder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority.												
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES (551.6, 551.7)											
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A										
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A										
3.0	AUTOMATIC DISCONNECTION OF SUPPLY											
3.1	Main earthing / bonding arrangements (411.3; Chap 54)	✓										
	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or Presence of installation earth electrode arrangement (542.1.2.3)	✓										
	Adequacy of earthing conductor size (542.3; 543.1.1)	✓										
	Adequacy of earthing conductor connections (542.3.2)	✓										
	Accessibility of earthing conductor connections (543.3.2)	✓										
	Adequacy of main protective bonding conductor sizes (544.1)	N/A										
	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	✓										
	Accessibility of all protective bonding connections (543.3.2)	✓										
	Provision of earthing / bonding labels at all appropriate locations (514.13)	✓										
3.2	FELV - requirements satisfied (411.7; 411.7.1)	N/A										
4.0	OTHER METHODS OF PROTECTION (Where any of the methods listed below are employed details should be provided on separate sheets)											
4.1	Non-conducting location (418.1)	N/A										
4.2	Earth-free local equipotential bonding (418.2)	N/A										
4.3	Electrical separation (Section 413; 418.3)	N/A										
4.4	Double insulation (Section 412)	✓										
4.5	Reinforced insulation (Section 412)	N/A										
5.0	DISTRIBUTION EQUIPMENT											
5.1	Adequacy of working space / accessibility to equipment (132.12; 513.1)	✓										
5.2	Security of fixing (134.1.1)	✓										
5.3	Condition of insulation of live parts (416.1)	✓										
5.4	Adequacy / security of barriers (416.2)	✓										
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	✓										
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	✓										
5.7	Enclosure not damaged / deteriorated so as to impair safety (651.2)	✓										
5.8	Presence and effectiveness of obstacles (417.2)	✓										
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	✓										
5.10	Operation of main switch(es) (functional check) (643.10)	✓										
5.11	Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10)	✓										
5.12	Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check) (643.10)	✓										
5.13	RCD(s) provided for fault protection – includes RCBOs (411.4.204; 411.5.2; 531.2)	N/A										
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBOs (411.3.3; 415.1)	✓										
5.15	Presence of RCD six-monthly test notice where required (514.12.2)	✓										
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	✓										





# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

Certificate No.

451

Page 4 of 15

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item	Description	Outcome (Use codes above. Provide additional comment where appropriate. C1, C2, C3 & FI coded items to be recorded under observations in the Condition Report)										
<b>5.0</b>	<b>DISTRIBUTION EQUIPMENT - continued</b>											
5.17	Presence of alternative supply warning notice at or near equipment, where required (514.15)								N/A			
5.18	Presence of next inspection recommendation label (514.12.1)								C3			
5.19	Presence of other required labelling (please specify) (Section 514)								✓			
5.20	Compatibility of protective device(s), base(s) and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4, .5 .6; sections 432, 433)								✓			
5.21	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.3)								✓			
5.22	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)								✓			
5.23	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)								✓			
<b>6.0</b>	<b>DISTRIBUTION CIRCUITS</b>											
6.1	Identification of conductors (514.3.1)											
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)											
6.3	Condition of insulation of live parts (416.1)											
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)											
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)											
6.6	Cables correctly terminated in enclosures (526)											
6.7	Confirmation that all conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)											
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage / deterioration (421.1; 522.6)											
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)											
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)											
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)											
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)											
6.13	Cable installation methods / practices with regard to the type and nature of installation and external influences (Section 522)											
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)											
6.15	Cables concealed under floors, above ceilings, in walls / partitions less than 50 mm from a surface, and in partitions containing metal parts											
	1. installed in prescribed zones ( see Extent and limitations) (522.6.202) or											
	2. incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Extent and Limitations) (522.6.204)											
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)											
6.17	Band II cables segregated / separated from Band I cables (528.1)											
6.18	Cables segregated / separated from non-electrical services (528.3)											
6.19	Condition of circuit accessories (651.2)											
6.20	Suitability of circuit accessories for external influences (512.2)											
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)											
6.22	Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment – identify / record numbers and locations of items inspected (Section 526)											
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; Section 537)											
6.24	General condition of wiring systems (651.2)											
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)											
<b>7.0</b>	<b>FINAL CIRCUITS</b>											
7.1	Identification of conductors (514.3.1)								✓			
7.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)								✓			
7.3	Condition of insulation of live parts (416.1)								✓			



# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

Certificate No.

451

Page 5 of 15

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item	Description	Outcome (Use codes above. Provide additional comment where appropriate. C1, C2, C3 & FI coded items to be recorded under observations in the Condition Report)										
<b>7.0</b>	<b>FINAL CIRCUITS - continued</b>											
7.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	✓										
7.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓										
7.6	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Sec. 523)	✓										
7.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓										
7.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓										
7.9	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓										
7.10	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓										
7.11	Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204)	N/V										
	1. installed in prescribed zones (see Extent and limitations) (522.6.202)	N/V										
	2. incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Extent and Limitations) (522.6.201; 522.6.204)	N/A										
7.12	Provision of additional protection by 30 mA RCD	✓										
	1. * for all socket-outlets of rating 32 A or less, unless an exception is permitted (411.3.3)	✓										
	2. * for the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓										
	3. * for cables concealed in walls at a depth of less than 50mm (522.6.202, .203)	✓										
	4. * for cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)	✓										
	5. * for final circuits supplying luminaires within domestic (household) premises (411.3.4)	N/A										
7.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓										
7.14	Band II cables segregated / separated from Band I cables (528.1)	✓										
7.15	Cables segregated / separated from non-electrical services (528.3)	✓										
7.16	Termination of cables at enclosures – identify / record numbers and locations of items inspected (Section 526)	✓										
	1. Connections under no undue strain (526.6)	✓										
	2. No basic insulation of a conductor visible outside enclosure (526.8)	✓										
	3. Connections of live conductors adequately enclosed (526.5)	✓										
	4. Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓										
7.17	Condition of accessories including socket-outlets, switches and joint boxes (651.2)	✓										
7.18	Suitability of accessories for external influences (512.2)	✓										
7.19	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	✓										
<b>8.0</b>	<b>ISOLATION AND SWITCHING</b>											
8.1	Isolators (Sections 460; 537)	✓										
	1. Presence and condition of appropriate devices (Section 462; 537.2.7)	✓										
	2. Acceptable location – state if local or remote from equipment in question (Section 462, 537.2.7)	✓										
	3. Capable of being secured in the OFF position (462.3)	N/A										
	4. Correct operation verified (643.10)	✓										
	5. Clearly identified by position and /or durable marking (537.2.6)	✓										
	6. Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	N/A										
8.2	Switching off for mechanical maintenance (Section 464; 537.3.2)	✓										
	1. Presence and condition of appropriate devices (461.1; 537.3.2)	✓										
	2. Acceptable location – state if local or remote from equipment in question (537.3.2.4)	✓										
	3. Capable of being secured in the OFF position (462.3)	N/A										
	4. Correct operation verified (643.10)	✓										
	5. Clearly identified by position and /or durable marking (537.3.2.4)	✓										

\* Older installations designed prior to BS 7671:2018 may not have been provided with RCDs for additional protection



# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

Certificate No.

451

Page 6 of 15

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item	Description	Outcome (Use codes above. Provide additional comment where appropriate. C1, C2, C3 & FI coded items to be recorded under observations in the Condition Report)										
8.0	ISOLATION AND SWITCHING - continued											
8.3	Emergency switching / stopping (Section 465; 537.3.3)	N/A										
	1. Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	✓										
	2. Readily accessible for operation where danger might occur (537.3.3.6)	✓										
	3. Correct operation verified (643.10)	✓										
	4. Clearly identified by position and /or durable marking (537.3.3.6)	✓										
8.4	Functional switching (Section 463; 537.3.1)											
	1. Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓										
	2. Correct operation verified (537.3.1.1; 537.3.1.2)	✓										
9.0	CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)											
9.1	Condition of equipment in terms of IP rating etc (416.2)	✓										
9.2	Equipment does not constitute a fire hazard (Section 421)	✓										
9.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓										
9.4	Suitability for the environment and external influences (512.2)	✓										
9.5	Security of fixing (134.1.1)	✓										
9.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	✓										
9.7	Recessed luminaires (downlighters)	N/A										
	1. Correct type of lamps fitted (559.3.1)	✓										
	2. Installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓										
	3. No signs of overheating to surrounding building fabric (559.4.1)	✓										
	4. No signs of overheating to conductors / terminations (526.1)	✓										
10.0	SPECIAL INSTALLATIONS OR LOCATIONS											
	If any special installations or locations are present, list the particular inspections applied.	N/A										

## GUIDANCE FOR RECIPIENTS

This Report is an important and valuable document which should be retained for future reference.

- The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see SUMMARY OF THE CONDITION OF THE INSTALLATION). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see OBSERVATIONS).
- The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.
- The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
- Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested six monthly. For safety reasons it is important that this instruction is followed.
- The section titled EXTENT AND LIMITATIONS should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

- Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in EXTENT AND LIMITATIONS.
- For items classified in OBSERVATIONS as C1 ("Danger present"), the safety of those using the installation is at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.
- For items classified in OBSERVATIONS as C2 ("Potentially dangerous"), the safety of those using the installation may be at risk and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
- Where it has been stated in OBSERVATIONS that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see RECOMMENDATIONS).
- For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in the Report under RECOMMENDATIONS and on a label at or near to the consumer unit/distribution board.

Inspected by:  
Name (Capitals)

C. ALLEN

Signature

C. Allen

Date

12/3/25



**Acknowledgement:** this certificate is based on the model in appendix 6 of BS 7671: 2018

451

7 of 15

14514  
RESTAURANT





**Certificate No.**

451

8 of 12

**TC5 / 18**



# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Certificate No.

451

Page 9 of 15

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

CLIENT DETAILS		INSTALLATION ADDRESS	
MRS WATSON		WILLOT OPHOLSPRY	
Postcode		Postcode	
PURPOSE FOR WHICH THIS REPORT IS REQUIRED			
CLIENTS REQUEST			
Date(s) on which inspection and testing was carried out: 12/3/2025			
DESCRIPTION OF PREMISES			
Domestic <input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Other (include description)			
Estimated age of the wiring system: Years 30			
Evidence of Alterations / Additions: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Not apparent <input type="checkbox"/> If 'Yes' estimate age in years 5			
Date of last inspection: UNKNOWN Records available: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
Extent of electrical installation covered by this report		Agreed Limitations (See Reg 653.2)	
SUPPLIERS EQUIPMENT, EARTHING		Agreed with	
ARRANGEMENTS, CONSUMER UNIT,		Operational limitations	
FINAL CIRCUITS			
It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground, have <b>not</b> been inspected unless specifically agreed between the client and the inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment. This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations), as amended to:			
SUMMARY OF THE CONDITION OF THE INSTALLATION			
General condition of the installation (in terms of electrical safety)			
Overall assessment of the installation in terms of its suitability for continued use: Satisfactory <input type="checkbox"/> Unsatisfactory* <input type="checkbox"/>			
*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.			
RECOMMENDATIONS & NEXT INSPECTION			
Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (Code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration.			
Subject to the necessary remedial action being taken, I/We recommend that this installation is further inspected and tested by (Date)			
for the following reasons			
DECLARATION			
I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations of this report.			
Inspected and tested by:		Report authorised for issue by:	
Name Capitals C ARCHER	Date 12/3/25	Name Capitals C ARCHER	Date 12/3/25
Signature		Signature	
For/on behalf of CR ARCHER ELECTRICAL LTD		For/on behalf of	
Position INSPECTOR		Position	
Address 14 ESMEAD, CHIPPENHAM,		Address	
WILTSHIRE, SN15 3PS			
CP Scheme: N/A <input checked="" type="checkbox"/>		Membership No:	



# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

Certificate No.

451

Page 10 of 15

## SUPPLY CHARACTERISTICS & EARTHING ARRANGEMENTS

Earthing Arrangements		Number of Live Conductors		Nature of Supply Parameters	
TN-C	TN-S	Phase / Wire	2 AC <input checked="" type="checkbox"/> DC <input type="checkbox"/>	Nominal Voltage $U/U_0$ 230/230 V	
TN-C-S <input checked="" type="checkbox"/>	TT	Other		Nominal Frequency $f^*$ 50 Hz	
IT		Confirmation of supply polarity <input checked="" type="checkbox"/>		Prospective fault current $I_{pf}^{\dagger}$ 2.2 kA	
Supply Protective Device Characteristics				External loop impedance $Z_e^{\dagger}$ 0.11 $\Omega$	
Type	136	Nominal current rating	100 A	* by enquiry <input type="checkbox"/> † by enquiry or by measurement <input checked="" type="checkbox"/>	
Other sources of supply (as detailed on attached schedule) N/A					

## PARTICULARS OF INSTALLATION REFERRED TO IN THE REPORT

Means of Earthing	Details of Installation Earth Electrode (where applicable)
Distributor's facility <input checked="" type="checkbox"/>	Type [eg. rod(s) tape etc]
Installation earth electrode <input type="checkbox"/>	Electrode resistance to Earth $\Omega$
	Location

## Main Protective Conductors

Earthing conductor:	Material Copper	csa 16 mm <sup>2</sup>	Continuity and connection verified <input checked="" type="checkbox"/>
Main protective bonding conductors: (to extraneous-conductors-parts)	Material Copper	csa 10 mm <sup>2</sup>	Continuity and connection verified <input checked="" type="checkbox"/>
To water installation pipes <input checked="" type="checkbox"/>	To gas installation pipes <input type="checkbox"/>	To oil installation pipes <input type="checkbox"/>	To structural steel <input type="checkbox"/>
To lightning protection <input type="checkbox"/>	To other <input type="checkbox"/> Specify		

## Main Switch / Switch - Fuse / Circuit-Breaker / RCD

BS, Type	61008	No. of poles	2	Voltage rating	230 V
Location	By meter BASEMENT WORKSHOP	Current rating	80 A	Fuse / device rating or setting	N/A A
If RCD main switch: Rated residual operating current $I_{\Delta n}$ = 30 mA Type <input type="checkbox"/> Rated time delay <input type="checkbox"/> ms Measured operating time 8.7 ms					

## OBSERVATIONS

Referring to the attached schedules of inspection and test results, and subject to the limitations specified at the **Extent and limitations of inspection and testing** section. No remedial action is required ☐ The following observations are made ☐ See below

OBSERVATIONS (Include schedule reference as appropriate)	CLASSIFICATION CODE
5.6 CORROSION ON HOT METAL	C3
5.15 TEST NOTICE NOT PRESENT	C3
5.17 " " " "	C3
5.17 MIXED COLOURS NOTICE NOT PRESENT	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action. **C1** - Danger present. Risk of injury. Immediate remedial action required. **C2** - Potentially dangerous - urgent remedial action required **C3** - Improvement recommended **F1** - Further investigation required without delay.

## Schedules

The attached Schedules are part of this document and this Certificate is valid only when they are attached to it.

No. of Inspection Schedules attached:

No. of Test Result Schedules attached:





# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Certificate No.

451

Page 11 of 15

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item	Description	Outcome (Use codes above. Provide additional comment where appropriate. C1, C2, C3 & FI coded items to be recorded under observations in the Condition Report)										
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)											
1.1	Service cable	✓										
1.2	Service head	✓										
1.3	Earthing arrangements	✓										
1.4	Meter tails	✓										
1.5	Metering equipment	✓										
1.6	Isolator (where present)	N/A										
Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and/or duty holder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority.												
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES (551.6, 551.7)											
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A										
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A										
3.0	AUTOMATIC DISCONNECTION OF SUPPLY											
3.1	Main earthing / bonding arrangements (411.3; Chap 54)	✓										
	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or Presence of installation earth electrode arrangement (542.1.2.3)	✓										
	Adequacy of earthing conductor size (542.3; 543.1.1)	✓										
	Adequacy of earthing conductor connections (542.3.2)	✓										
	Accessibility of earthing conductor connections (543.3.2)	✓										
	Adequacy of main protective bonding conductor sizes (544.1)	✓										
	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	✓										
	Accessibility of all protective bonding connections (543.3.2)	✓										
	Provision of earthing / bonding labels at all appropriate locations (514.13)	✓										
3.2	FELV - requirements satisfied (411.7; 411.7.1)	N/A										
4.0	OTHER METHODS OF PROTECTION (Where any of the methods listed below are employed details should be provided on separate sheets)											
4.1	Non-conducting location (418.1)											
4.2	Earth-free local equipotential bonding (418.2)											
4.3	Electrical separation (Section 413; 418.3)											
4.4	Double insulation (Section 412)	✓										
4.5	Reinforced insulation (Section 412)											
5.0	DISTRIBUTION EQUIPMENT											
5.1	Adequacy of working space / accessibility to equipment (132.12; 513.1)	✓										
5.2	Security of fixing (134.1.1)	✓										
5.3	Condition of insulation of live parts (416.1)	✓										
5.4	Adequacy / security of barriers (416.2)	✓										
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	✓										
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	C3										
5.7	Enclosure not damaged / deteriorated so as to impair safety (651.2)	✓										
5.8	Presence and effectiveness of obstacles (417.2)	✓										
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	✓										
5.10	Operation of main switch(es) (functional check) (643.10)	✓										
5.11	Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10)	✓										
5.12	Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check) (643.10)	✓										
5.13	RCD(s) provided for fault protection – includes RCBOs (411.4.204; 411.5.2; 531.2)	N/A										
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBOs (411.3.3; 415.1)	✓										
5.15	Presence of RCD six-monthly test notice where required (514.12.2)	C3										
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	✓										



# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

Certificate No.

451

Page 12 of 15

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item	Description	Outcome (Use codes above. Provide additional comment where appropriate. C1, C2, C3 & FI coded items to be recorded under observations in the Condition Report)										
<b>5.0</b>	<b>DISTRIBUTION EQUIPMENT - continued</b>											
5.17	Presence of alternative supply warning notice at or near equipment, where required (514.15)	N/A										
5.18	Presence of next inspection recommendation label (514.12.1)	C3										
5.19	Presence of other required labelling (please specify) (Section 514)	N/A										
5.20	Compatibility of protective device(s), base(s) and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4, .5 .6; sections 432, 433)	✓										
5.21	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.3)	✓										
5.22	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	✓										
5.23	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	N/A										
<b>6.0</b>	<b>DISTRIBUTION CIRCUITS</b>											
6.1	Identification of conductors (514.3.1)											
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)											
6.3	Condition of insulation of live parts (416.1)											
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)											
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)											
6.6	Cables correctly terminated in enclosures (526)											
6.7	Confirmation that all conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)											
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage / deterioration (421.1; 522.6)											
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)											
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)											
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)											
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)											
6.13	Cable installation methods / practices with regard to the type and nature of installation and external influences (Section 522)											
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)											
6.15	Cables concealed under floors, above ceilings, in walls / partitions less than 50 mm from a surface, and in partitions containing metal parts											
	1. installed in prescribed zones ( see Extent and limitations) (522.6.202) or											
	2. incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Extent and Limitations) (522.6.204)											
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)											
6.17	Band II cables segregated / separated from Band I cables (528.1)											
6.18	Cables segregated / separated from non-electrical services (528.3)											
6.19	Condition of circuit accessories (651.2)											
6.20	Suitability of circuit accessories for external influences (512.2)											
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)											
6.22	Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment – identify / record numbers and locations of items inspected (Section 526)											
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; Section 537)											
6.24	General condition of wiring systems (651.2)											
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)											
<b>7.0</b>	<b>FINAL CIRCUITS</b>											
7.1	Identification of conductors (514.3.1)	✓										
7.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓										
7.3	Condition of insulation of live parts (416.1)	✓										



# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Certificate No.

451

Page 13 of 15

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item	Description	Outcome (Use codes above. Provide additional comment where appropriate. C1, C2, C3 & FI coded items to be recorded under observations in the Condition Report)										
7.0	FINAL CIRCUITS - continued											
7.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	✓										
7.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓										
7.6	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Sec. 523)	✓										
7.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓										
7.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓										
7.9	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓										
7.10	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓										
7.11	Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204)	N/A										
	1. installed in prescribed zones (see Extent and limitations) (522.6.202)											
	2. incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Extent and Limitations) (522.6.201; 522.6.204)											
7.12	Provision of additional protection by 30 mA RCD	✓										
	1. * for all socket-outlets of rating 32 A or less, unless an exception is permitted (411.3.3)	✓										
	2. * for the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓										
	3. * for cables concealed in walls at a depth of less than 50mm (522.6.202, .203)	✓										
	4. * for cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)	✓										
	5. * for final circuits supplying luminaires within domestic (household) premises (411.3.4)	N/A										
7.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓										
7.14	Band II cables segregated / separated from Band I cables (528.1)	✓										
7.15	Cables segregated / separated from non-electrical services (528.3)	✓										
7.16	Termination of cables at enclosures – identify / record numbers and locations of items inspected (Section 526)	✓										
	1. Connections under no undue strain (526.6)	✓										
	2. No basic insulation of a conductor visible outside enclosure (526.8)	✓										
	3. Connections of live conductors adequately enclosed (526.5)	✓										
	4. Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓										
7.17	Condition of accessories including socket-outlets, switches and joint boxes (651.2)	✓										
7.18	Suitability of accessories for external influences (512.2)	✓										
7.19	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	✓										
8.0	ISOLATION AND SWITCHING											
8.1	Isolators (Sections 460; 537)	✓										
	1. Presence and condition of appropriate devices (Section 462; 537.2.7)	✓										
	2. Acceptable location – state if local or remote from equipment in question (Section 462, 537.2.7)	✓ LOCAL										
	3. Capable of being secured in the OFF position (462.3)	N/A										
	4. Correct operation verified (643.10)	✓										
	5. Clearly identified by position and /or durable marking (537.2.6)	✓										
	6. Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	N/A										
8.2	Switching off for mechanical maintenance (Section 464; 537.3.2)	✓										
	1. Presence and condition of appropriate devices (461.1; 537.3.2)	✓										
	2. Acceptable location – state if local or remote from equipment in question (537.3.2.4)	✓ LOCAL										
	3. Capable of being secured in the OFF position (462.3)	N/A										
	4. Correct operation verified (643.10)	✓										
	5. Clearly identified by position and /or durable marking (537.3.2.4)	✓										

\* Older installations designed prior to BS 7671:2018 may not have been provided with RCDs for additional protection



# ELECTRICAL INSTALLATION CONDITION REPORT cont.

Acknowledgement: this certificate is based on the model in Appendix 6 of BS 7671: 2018

Certificate No.

451

Page 14 of 15

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item	Description								Outcome (Use codes above. Provide additional comment where appropriate. C1, C2, C3 & FI coded items to be recorded under observations in the Condition Report)			
8.0	ISOLATION AND SWITCHING - continued											
8.3	Emergency switching / stopping (Section 465; 537.3.3)								N/A			
	1. Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)											
	2. Readily accessible for operation where danger might occur (537.3.3.6)											
	3. Correct operation verified (643.10)											
	4. Clearly identified by position and /or durable marking (537.3.3.6)											
8.4	Functional switching (Section 463; 537.3.1)											
	1. Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)											
	2. Correct operation verified (537.3.1.1; 537.3.1.2)											
9.0	CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)											
9.1	Condition of equipment in terms of IP rating etc (416.2)								✓			
9.2	Equipment does not constitute a fire hazard (Section 421)								✓			
9.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)								✓			
9.4	Suitability for the environment and external influences (512.2)								✓			
9.5	Security of fixing (134.1.1)								✓			
9.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)								✓			
9.7	Recessed luminaires (downlighters)								N/A			
	1. Correct type of lamps fitted (559.3.1)											
	2. Installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)											
	3. No signs of overheating to surrounding building fabric (559.4.1)											
	4. No signs of overheating to conductors / terminations (526.1)											
10.0	SPECIAL INSTALLATIONS OR LOCATIONS											
	If any special installations or locations are present, list the particular inspections applied.								N/A			

## GUIDANCE FOR RECIPIENTS

This Report is an important and valuable document which should be retained for future reference.

- The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see SUMMARY OF THE CONDITION OF THE INSTALLATION). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see OBSERVATIONS).
- The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.
- The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
- Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested six monthly. For safety reasons it is important that this instruction is followed.
- The section titled EXTENT AND LIMITATIONS should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

- Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in EXTENT AND LIMITATIONS.
- For items classified in OBSERVATIONS as C1 ("Danger present"), the safety of those using the installation is at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.
- For items classified in OBSERVATIONS as C2 ("Potentially dangerous"), the safety of those using the installation may be at risk and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
- Where it has been stated in OBSERVATIONS that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see RECOMMENDATIONS).
- For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in the Report under RECOMMENDATIONS and on a label at or near to the consumer unit/distribution board.

Inspected by: Name (Capitals)	C. ALLER	Signature		Date	12/13/2025
----------------------------------	----------	-----------	--	------	------------





## Page 15 of 15

451

TC5 / 18

