

# Energy performance certificate (EPC)

Unit 7  
Harvester Way  
Peterborough  
PE1 5UT

Energy rating

C

Valid until:

6 July 2031

Certificate number:

2295-9262-6103-8522-9410

Property type

B8 Storage or Distribution

Total floor area

218 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

The figure shows a horizontal bar chart representing the energy rating scale. The scale consists of eight colored bars, each representing a rating from A+ to G. The bars are arranged in descending order of rating. A green arrow points to the 'C' rating bar, which is labeled with the score '74 C'. A vertical line labeled 'Net zero CO2' is positioned between the 'A' and 'B' rating bars.

Rating	Score Range
A+	Under 0
A	0-25
B	26-50
C	51-75
D	76-100
E	101-125
F	126-150
G	Over 150

<https://find-energy-certificate.service.gov.uk/energy-certificate/2295-9262-6103-8522-9410?print=true>

1/3

How this property compares to others

Properties similar to this one could have ratings:

If newly built	29 B
If typical of the existing stock	86 D

Breakdown of this property’s energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	5
Building emission rate (kgCO2/m2 per year)	63.19
Primary energy use (kWh/m2 per year)	374

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/7652-5570-5069-3165-2624\)](#).

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Joe Davies
Telephone	07977 513353
Email	<a href="mailto:joe.davies@meessolutions.co.uk">joe.davies@meessolutions.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA206152
Telephone	020 8772 3649
Email	<a href="mailto:epc@cibsecertification.org">epc@cibsecertification.org</a>

### About this assessment

Employer	MEES Solutions Limited
Employer address	85 Great Portland Street, First Floor, London, W1W 7LT
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	10 June 2021
Date of certificate	7 July 2021

---