

Total floor area

A3/A4/A5 Restaurant and Cafes/Drinking Establishments and Hot Food takeaways


616 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

#### **Energy rating and score**

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

| If newly built                   | 28 B |
|----------------------------------|------|
| If typical of the existing stock | 81 D |

# Breakdown of this property's energy performance

| Main heating fuel                          | Natural Gas                     |
|--|---------------------------------|
| Building environment                       | Heating and Natural Ventilation |
| Assessment level                           | 3                               |
| Building emission rate (kgCO2/m2 per year) | 150.93                          |
| Primary energy use (kWh/m2 per year)       | 874                             |

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the  $\underline{\text{recommendation report}}$   $\underline{\text{(/energy-certificate/0640-0241-4939-8094-6006)}}$ .

### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

| Assessor's name | Richard Siddall                 |
|-----------------|---------------------------------|
| Telephone       | 02476 233144                    |
| Email           | richard.siddall@wensleylawz.com |

#### **Contacting the accreditation scheme**

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

| Accreditation scheme  | Elmhurst Energy Systems Ltd    |
|-----------------------|--------------------------------|
| Assessor's ID         | EES/007509                     |
| Telephone             | 01455 883 250                  |
| Email                 | enquiries@elmhurstenergy.co.uk |
| About this assessment |                                |
| Employer              | Wensley And Lawz Ltd           |

| Employer               | Wensley And Lawz Ltd                                      |
|------------------------|---|
| Employer address       | 116 Walsgrave Road National Westminster Building          |
|                        | Coventry CV2 4ED  |
| Assessor's declaration | The assessor is not related to the owner of the property. |
| Date of assessment     | 16 April 2019   |
| Date of certificate    | 1 May 2019  |