

Energy performance certificate (EPC)

Cat & Fiddle Macclesfield Forest MACCLESFIELD SK11 0AR	Energy rating C	Valid until: 8 January 2030
		Certificate number: 9920-7967-0321-3340-2004


Property type	A3/A4/A5 Restaurant and Cafes/Drinking Establishments and Hot Food takeaways
Total floor area	814 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

27 B

If typical of the existing stock

80 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	88.15
Primary energy use (kWh/m ² per year)	507

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9730-4042-0612-0290-3795\)](https://energy-certificate/9730-4042-0612-0290-3795).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Matthew Burgess
Telephone	08443 270365
Email	epc@compliance365.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID300243
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	Compliance365
Employer address	6 Mariner Court
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	17 December 2019
Date of certificate	9 January 2020