Find an energy certificate (/)

English | Cymraeg

# **Energy performance certificate** (EPC) recommendation report

**Tatton Arms** 3-5 Tipping Street **ALTRINCHAM** WA14 2EZ

Report number 0912-5878-0482-9371-1101

> Valid until 18 January 2033

### **Energy rating and EPC**

This property's energy rating is C.

For more information on the property's energy performance, see the EPC for this property (/energy-certificate/8249-1225-6438-7140-8737).

### Recommendations

#### Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
Install more efficient water heater.	High
Consider replacing HWS with point of use system.	High
Consider replacing T8 lamps with retrofit T5 conversion kit.	Medium
Changes that may pay for themselves within 3 to 7 years	i
Recommendation	Potential impact on carbon emissions
Some windows have high U-values - consider installing secondary glazing.	Medium

Recommendation	Potential impact on carbon emissions
Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	Low
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	Medium
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	Medium
Changes that may pay for themselves in over 7 years	
Recommendation	Potential impact on carbon emissions
Consider installing building mounted wind turbine(s).	Low
Roof is poorly insulated. Install or improve insulation of roof.	Medium
Consider installing solar water heating.	Low
Consider installing PV.	Low
Additional recommendations	
Recommendation	Potential impact on carbon emissions
Add optimum start/stop to the heating system.	Medium
Add weather compensation controls to heating system.	Medium
Add local time control to heating system.	Medium
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	High
Consider switching from gas to biomass.	High

## **Property and report details**

Report issued on	19 January 2023
Total useful floor area	324 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	Elmhurst Energy Systems Ltd, SBEM Online, v6.01, SBEM, v6.1.b.0

### Assessor's details

Assessor's name	Lionel Braceiner
Telephone	07813139837
Email	lionel@bandheco.co.uk
Employer's name	Imb commercial Itd
Employer's address	60 Cavendish Road, Manchester, M7 4WA
Assessor ID	EES/019534
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Elmhurst Energy Systems Ltd

### Other reports for this property

If you are aware of previous reports for this property and they are not listed here, please contact us at <a href="mailto:mhclg.digital-services@communities.gov.uk">mhclg.digital-services@communities.gov.uk</a> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Expired on	5 March 2019
Report number	0070-7097-0401-6640-5000 (/energy-certificate/0070-7097-0401-6640-5000)
Expired on	7 December 2019
Report number	0970-7097-0401-6140-5004 (/energy-certificate/0970-7097-0401-6140-5004)



Help (/help) Accessibility (/accessibility-statement) Cookies (/cookies)

Give feedback (https://forms.office.com/e/KX25htGMX5)

Service performance (/service-performance)



All content is available under the <u>Open Government</u> <u>Licence v3.0 (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/)</u>, except where otherwise stated



© Crown copyright (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/)