

Energy performance certificate (EPC) recommendation report

Rose & Crown
20 Bondgate
OTLEY
LS21 1AD

Report number
0920-6962-0468-9670-9010

Valid until
27 February 2028

Energy rating and EPC

This property’s energy rating is E.

For more information on the property’s energy performance, [see the EPC for this property \(/energy-certificate/0660-0938-9669-1792-2006\)](#).

Recommendations

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.	Low
Improve insulation on HWS storage.	Low
Consider replacing T8 lamps with retrofit T5 conversion kit.	Medium
Add time control to heating system.	Low
Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	Low
Add optimum start/stop to the heating system.	Medium

Recommendation	Potential impact on carbon emissions
The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.	Low

Some walls have uninsulated cavities - introduce cavity wall insulation.

Medium

Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Some windows have high U-values - consider installing secondary glazing.	Medium
Add local temperature control to the heating system.	Medium
Add weather compensation controls to heating system.	Medium
Add local time control to heating system.	Medium
Consider replacing heating boiler plant with a condensing type.	High
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	Medium

Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	Medium
Consider installing an air source heat pump.	High
Consider installing a ground source heat pump.	High
Consider installing building mounted wind turbine(s).	Low
Roof is poorly insulated. Install or improve insulation of roof.	Medium

Property and report details

Report issued on	28 February 2018
Total useful floor area	284 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	DesignBuilder Software Ltd, DesignBuilder SBEM, v5.0.3, SBEM, v5.3.a.0

Assessor's details

Assessor's name	Michael Vasey
Telephone	01924 669 940
Email	michaelvasey@live.co.uk
Employer's name	Compliance365
Employer's address	6 Mariner Court
Assessor ID	QUID206680
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Quidos Limited

Other reports for this property

If you are aware of previous reports for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related reports for this property.



[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5)

[Service performance \(/service-performance\)](#)

OGL

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



© Crown copyright (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/>)