

Display energy certificate (DEC)



HM Government

Inspiring Healthy Lifestyles
SUMMIT INDOOR ADVENTURE
SELBY LEISURE VILLAGE
SCOTT ROAD
SELBY
YO8 4BL

Operational rating

A

Certificate number: 0570-4414-7602-0526-1806

Valid until: 29 June 2025

Total useful floor area: 2,735.84 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A	16 A	
26-50	B		
51-75	C		
76-100	D		
			100
101-125	E		
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
June 2024	16 A
June 2023	20 A
June 2022	27 B

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
June 2024	44	18	0
June 2023	53	24	0
June 2022	81	21	0

Assessment details

Assessor's name	Andrew Morphet
Employer/Trading name	Synergy Property Services Ltd
Employer/Trading address	20 Fieldon Drive, Grendon, Atherstone CV9 2FT
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	25 June 2024
Nominated date	30 June 2024

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	28.94	34.30
Typical energy use (kWh/m ² /year)	123.36	377.06
Energy from renewables	0%	0%

