Energy performance certificate (EPC)

Unit 5 Southampton Trade Park Third Avenue SOUTHAMPTON SO15 0AD Energy rating

Valid until: 27 August 2029

Certificate number:

0596-2985-8930-2800-5103

Property type B8 Storage or Distribution


Total floor area 386 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

27 B

If typical of the existing stock

80 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	75.4
Primary energy use (kWh/m2 per year)	440

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/0280-5985-0481-5290-9064).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Paul Harris
Telephone	01327811166
Email	paul.harris@socotec.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO034308
Telephone	0330 124 9660
Email	certification@stroma.com
About this assessment	

Employer	SOCOTEC LTD
Employer address	Bretby Business Park Ashby Road Burton-on-trent
	DERBYSHIRE DE15 0YZ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	22 August 2019
Date of certificate	28 August 2019