Energy performance certificate (EPC)

F6 6 Whittle Road FERNDOWN BH21 7RU Energy rating

Valid until: 8 February 2035

Certificate number: 1508-9869-3610-9716-5314

Property type Offices and Workshop Businesses


Total floor area 115 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is A.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If typical of the existing stock

If newly built

9 A

34 B

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	4.83
Primary energy use (kWh/m2 per year)	50

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\underline{\text{recommendation report}}$ ($\underline{\text{recommendation report}}$).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mark Sturman
Telephone	07813953516
Email	mark.sturman@mlsproperty.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/027612
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment	
Employer	MLS Property Consultants Limited
Employer address	13 Clifton Road, Poole, Dorset, BH14 9PW
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	4 February 2025
Date of certificate	9 February 2025