

Energy performance certificate (EPC)

1-4 Cobblestone Way
Newark East
PETERBOROUGH
PE1 5WJ

Energy rating

A

Valid until:

2 January 2028

Certificate number:

0090-3940-0388-0200-4034

Property type

B8 Storage or Distribution

Total floor area


2,501 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is A.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

26 B

If typical of the existing stock

77 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	4
Building emission rate (kgCO ₂ /m ² per year)	15.29
Primary energy use (kWh/m ² per year)	90

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9303-4009-0488-0400-2005\)](/energy-certificate/9303-4009-0488-0400-2005).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Robert Cameron
Telephone	01623 883020
Email	cam0nrg@gmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019783
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Cameron Energy Consultants Ltd
Employer address	Hexgreave Hall, Upper Hexgreave, Newark. NG22 8LS
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	2 January 2018
Date of certificate	3 January 2018
