

Energy performance certificate (EPC)

15, Reece Mews LONDON SW7 3HE	Energy rating C	Valid until: 22 August 2029
		Certificate number: 0130-0131-9139-0108-1006

Property type **B1 Offices and Workshop businesses**

Total floor area **98 square metres**

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's current energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

28 B

If typical of the existing stock

83 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	45.21
Primary energy use (kWh/m ² per year)	267

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0080-3911-0431-9110-1000\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Uruj Chanan
Telephone	07860564397
Email	office@lewisandchanan.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK
Assessor's ID	ECMK303192
Telephone	0333 123 1418
Email	info@ecmk.co.uk

About this assessment

Employer	Information not provided by the user
Employer address	Information not provided by the user
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	9 August 2019
Date of certificate	23 August 2019