

# Energy performance certificate (EPC)

Blaen Nant Gwyn  
The Old Bike Shed  
PENCADER  
SA39 9EH

Energy rating

**D**

Valid until: **30 May 2034**

Certificate number: **0330-2274-6050-2824-7721**

Property type: Semi-detached bungalow

Total floor area: 18 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy rating and score

This property's energy rating is D. It has the potential to be A.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

Score	Energy rating	Current	Potential
92+	<b>A</b>		137 <b>A</b>
81-91	<b>B</b>		
69-80	<b>C</b>		
55-68	<b>D</b>	56 <b>D</b>	
39-54	<b>E</b>		
21-38	<b>F</b>		
1-20	<b>G</b>		

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Roof	Pitched, insulated	Average
Window	Fully double glazed	Good
Main heating	Community scheme	Good
Main heating control	Flat rate charging, TRVs	Average
Hot water	Community scheme	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

### Primary energy use

The primary energy use for this property per year is 663 kilowatt hours per square metre (kWh/m<sup>2</sup>).

### Additional information

Additional information about this property:

- Stone walls present, not insulated
-

## How this affects your energy bills

An average household would need to spend **£892 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £381 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

---

### Heating this property

Estimated energy needed in this property is:

- 5,400 kWh per year for heating
- 1,616 kWh per year for hot water

---

### Impact on the environment

This property's environmental impact rating is F. It has the potential to be A.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

#### Carbon emissions

An average household produces 6 tonnes of CO<sub>2</sub>

This property produces 3.5 tonnes of CO<sub>2</sub>

This property's potential production -1.1 tonnes of CO<sub>2</sub>

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

---

### Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Internal or external wall insulation	£4,000 - £14,000	£283
2. Floor insulation (solid floor)	£4,000 - £6,000	£46
3. Solar water heating	£4,000 - £6,000	£51
4. Solar photovoltaic panels	£3,500 - £5,500	£556
5. Wind turbine	£15,000 - £25,000	£1,111

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](http://www.gov.uk/improve-energy-efficiency)

---

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Karl Collins
Telephone	07808085770
Email	<a href="mailto:karl@epcmyproperty.co.uk">karl@epcmyproperty.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/027844
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### About this assessment

Assessor's declaration	No related party
Date of assessment	24 May 2024
Date of certificate	31 May 2024
Type of assessment	<a href="#">RdSAP</a>

---