
Energy performance certificate (EPC)				
The Old Barn Bryn Goleu St Martins OSWESTRY SY11 3HF	Energy rating	Valid until:	2 June 2034	
		Certificate number:	7289-6004-8273-6042-2081	
Property type	C	offices and Work	shop Businesses	
Total floor area	244 square metres			

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

27 B

109 E

How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock



Main heating fuel	Oil
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	57.51
Primary energy use (kWh/m2 per year)	246

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/6510-2138-0934-2676-1969).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	leuan Stevens	
Telephone	07828 639998	
Email	info@dragon-energy.co.uk	

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd	
Assessor's ID	EES/018839	
Telephone	01455 883 250	
Email	enquiries@elmhurstenergy.co.uk	

About this assessment

Employer	Dragon Energy	
Employer address	13a Pencaemawr, Penegoes, Machynlleth SY20 8PF	
Assessor's declaration	The assessor is not related to the owner of the property.	
Date of assessment	28 May 2024	
Date of certificate	3 June 2024	