

Energy performance certificate (EPC)

13 Oswald Road
OSWESTRY
SY11 1RB

Energy rating

F

Valid until: 27 April 2032

Certificate number: 0300-2958-7140-2822-3531

Property type

Mid-floor maisonette

Total floor area

154 square metres

Rules on letting this property



You may not be able to let this property


This property has an energy rating of F. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Properties can be rented if they have an energy rating from A to E. The [recommendations section](#) sets out changes you can make to improve the property's rating.

Energy efficiency rating for this property

This property's current energy rating is F. It has the potential to be C.

[See how to improve this property's energy performance.](#)



The graph shows this property’s current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property’s energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says “assumed”, it means that the feature could not be inspected and an assumption has been made based on the property’s age and type.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Roof room(s), ceiling insulated	Poor
Window	Single glazed	Very poor

Feature	Description	Rating
Main heating	Electric storage heaters	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Manual charge control	Poor
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	Electric immersion, off-peak	Very poor
Lighting	Low energy lighting in 64% of fixed outlets	Good
Floor	(other premises below)	N/A
Secondary heating	Portable electric heaters (assumed)	N/A

Primary energy use

The primary energy use for this property per year is 530 kilowatt hours per square metre (kWh/m²).

► [What is primary energy use?](#)

Environmental impact of this property

This property's current environmental impact rating is F. It has the potential to be C.

Properties are rated in a scale from A to G based on how much carbon dioxide (CO₂) they produce.

Properties with an A rating produce less CO₂ than G rated properties.

An average household produces

6 tonnes of CO₂

This property produces

14.0 tonnes of CO₂

This property's potential production

3.5 tonnes of CO₂

By making the [recommended changes](#), you could reduce this property's CO₂ emissions by 10.5 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

Improve this property's energy performance

By following our step by step recommendations you could reduce this property's energy use and potentially save money.

Carrying out these changes in order will improve the property's energy rating and score from F (31) to C (78).

► [Do I need to follow these steps in order?](#)



Step 1: Room-in-roof insulation

Room-in-roof insulation

Typical installation cost

£1,500 - £2,700

Typical yearly saving

£645

Potential rating after completing step 1

41 | E

Step 2: Internal or external wall insulation

Internal or external wall insulation

Typical installation cost

£4,000 - £14,000

Typical yearly saving

£676

Potential rating after completing steps 1 and 2

55 | D

Step 3: Hot water cylinder insulation

Increase hot water cylinder insulation

Typical installation cost

£15 - £30

Typical yearly saving

£48

Potential rating after completing steps 1 to 3

56 | D

Step 4: Draught proofing

Draught proofing

Typical installation cost

£80 - £120

Typical yearly saving

£67

Potential rating after completing steps 1 to 4

57 | D

Step 5: Low energy lighting

Low energy lighting

Typical installation cost

£20

Typical yearly saving

£32

Potential rating after completing steps 1 to 5

58 | D

Step 6: Change heating to gas condensing boiler

Gas condensing boiler

Typical installation cost

£3,000 - £7,000

Typical yearly saving

£1,103

Potential rating after completing steps 1 to 6

76 | C

Step 7: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost

£3,300 - £6,500

Typical yearly saving

£72

Potential rating after completing steps 1 to 7

78 | C

Paying for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property

£3414

Potential saving

£2643

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The potential saving shows how much money you could save if you [complete each recommended step in order](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Type of heating**Estimated energy used**

Space heating

27492 kWh per year

Water heating

2542 kWh per year

Potential energy savings by installing insulation

Type of insulation

Amount of energy saved

Solid wall insulation

6392 kWh per year

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details**Assessor's name**Damian Pinson

Telephone0845 0945 192

Emailepcquery@vibrantenergymatters.co.uk

Accreditation scheme contact details**Accreditation scheme**Elmhurst Energy Systems Ltd

Assessor IDEES/018246

Telephone01455 883 250

Emailenquiries@elmhurstenergy.co.uk

Assessment details

Assessor's declaration

No related party

Date of assessment

28 April 2022

Date of certificate

28 April 2022

Type of assessment

► [RdSAP](#)

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.