

# Energy performance certificate (EPC)

19-20  
Hills Lane  
Shrewsbury  
SY1 1QU

Energy rating

E

Valid until: 15 November 2031

Certificate  
number: 2121-3790-8196-6694-9791

Property type

D2 General Assembly and Leisure plus Night Clubs  
and Theatres

Total floor area

528 square metres

## Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

## Energy efficiency rating for this property

This property's current energy rating is E.



Properties are also given a score. The larger the number, the more carbon dioxide (CO<sub>2</sub>) your property is likely to emit.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

32 | B

If typical of the existing stock

94 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

# Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	103.73
Primary energy use (kWh/m2 per year)	614

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/7914-8649-2162-1990-7692\)](/energy-certificate/7914-8649-2162-1990-7692).

# Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

Assessor's name	Ceri Ransome
Telephone	(0)1952 594 877
Email	<a href="mailto:ceriransome@live.co.uk">ceriransome@live.co.uk</a>

## Accreditation scheme contact details

Accreditation scheme	Quidos Limited
Assessor ID	QUID201006
Telephone	01225 667 570
Email	<a href="mailto:info@quidos.co.uk">info@quidos.co.uk</a>

## Assessment details

Employer	CRHR
Employer address	15 Hafren Road, Little Dawley, Telford TF4 3HJ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	11 October 2021
Date of certificate	16 November 2021

---