

# Energy performance certificate (EPC)

	<b>B</b>	19 August 2034
		6805-0618-2058-2254-5963


Property type	Offices and Workshop Businesses
Total floor area	505 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built	14 A
If typical of the existing stock	57 C

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	4
Building emission rate (kgCO2/m2 per year)	15.48
Primary energy use (kWh/m2 per year)	165

## Recommendation report

Guidance on improving the energy performance of this property can be found in the \_\_\_\_\_.

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Joseph Lund
Telephone	01865865403
Email	_____

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/024073
Telephone	01455 883 250
Email	_____

### About this assessment

Employer	Carbon Profile
Employer address	Exchange House 314 Midsummer Blvd Milton Keynes MK9 2UB
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	8 August 2024
Date of certificate	20 August 2024